

**47 West Relugas Road EH9 2PW  
Planning Application 21/04132/FUL**

**OBJECTION from Grange Association  
17 September 2021**

This application includes the formation of hard-standing at the front of the property and the creation of a vehicle entrance by removing the present wall and hedge.

The Council's [Householder Guidance](#) specifies (page 19) that a vehicle entrance should be no wider than 3m. We see no reason why this entrance needs to be 3.4m wide, as proposed, and we request that the applicant be invited to adjust the proposals to comply with the Householder Guidance with a vehicle entrance no wider than 3m.

**Grange Association  
17 September 2021**